

**TAMIL NADU FIRE & RESCUE SERVICE STATION  
FIRE AND RESCUE SERVICE , CHENGALPTTU.**

RC.NO. 144/V/CPT/2022

Date: 16.03.2022

**NO OBJECTION CERTIFICATE**

Subject: Fire and Rescue Service , Chengalpattu NOC to Erect a School Building/Issue  
School Recognition – Reg.

Notice: 1) Govt. Order No.122 School Education (2) Dept.Day 14.09.2004  
2) Govt. Order No. 123 School Education (2) Dept.Day 14.09.2004


Application received from the Correspondent : 10.03.2022

As per the Govt.Order and the application, SRS VIDYA MANDIR CBSE SCHOOL situated at Thirukazhukundram Road, Vadakadambadi, Poonjeri Post, Mamallapuram, Chengalpattu District 603 104 was inspected by the Station Officer, Chengalpattu P. KARTHIKEYAN ( 15.03.2022) There is No Objection from the Department of Fire and Rescue a School Building at this place or to issue School Recognition.

**CONDITIONS**

1. This License is valid for One Year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupied load and to ensure better fire and life safety measures the following additional measures are insisted.
  - (a) Building occupancy capacity should not be more than 4 people per Sq.mt as per the National Building Code- 2005.
  - (b) The Staircase treads and flooring shall be treated with rough finish ( growing) to avoid falling of children.
  - (c) As per para 6.3 of the BIS Standards IS 14435; 1997 as the classrooms have only one entrance, the capacity of the class room shall have to be limited to 45 students.
  - (d) Periodical maintenance and care should be taken to maintain all fire protection equipments.
  - (e) Mock Drill has to be conducted at regular intervals in consultation with the Divisional Officer, Fire and Rescue Services, Kancheepuram District at Kancheepuram.

Office Seal



*P. Karthikeyan*  
Station Officer, 16/3/2022  
Fire and Rescue Station,  
Chengalpattu.

To  
**THE CORRESPONDENT,**  
SRS VIDYA MANDIR CBSE SCHOOL  
Thirukazhukundram Road,  
Vadakadambadi, Poonjeri Post,  
Mamallapuram,  
Chengalpattu District 603 104

Copy : District Officer, Chengalpattu District.